



NOTES:

1. ASPHALT CONCRETE PAVEMENT (ACP) IN THE PATCH ZONE SHALL BE CLASS B. MINIMUM THICKNESS SHALL BE 3 INCHES, OR MATCH EXISTING, WHICHEVER IS GREATER. HOWEVER, THE MAXIMUM THICKNESS IS NOT REQUIRED TO BE GREATER THAN 6 INCHES. MAXIMUM DEPTH OF LIFTS SHALL BE 3 INCHES (COMPACTED).
2. PATCH WIDTH MUST ACCOMODATE PROPER COMPACTION METHODS AS APPROVED BY THE PUBLIC WORKS DIRECTOR.
3. ALL CONSTRUCTION AND MATERIALS SHALL MEET THE SPECIFICATIONS AND BE APPROVED BY THE CITY OF EPHRATA.

PATCHING DETAIL

EPHRATA PUBLIC WORKS DEPARTMENT

DRAWN	
CHECK	
SCALE	NTS
DATE	10/03/08

CITY OF EPHRATA



15

DATE	REVISION	BY

