



DUCTILE IRON
DROP CONNECTION

NOTES:

1. ALL PIPING AND FITTINGS TO BE DUCTILE IRON AND BE WRAPPED IN 8-MIL POLYETHYLENE ENCASEMENT.
2. MANHOLE SHALL BE CONSTRUCTED PER PLAN '24'.
3. ALL DUCTILE IRON PIPE SHALL BE A MINIMUM OF CLASS 50.
4. DROP MANHOLE CONNECTIONS SHALL NOT BE CONSTRUCTED UNLESS APPROVED BY THE ENGINEER.
5. ALL CONSTRUCTION AND MATERIALS SHALL MEET THE SPECIFICATIONS AND BE APPROVED BY THE CITY OF EPHRATA.

DROP MANHOLE CONNECTION

EPHRATA PUBLIC WORKS DEPARTMENT

CITY OF EPHRATA

DRAWN

CHECK

SCALE NTS

DATE 10/03/08

GRANT COUNTY

WASHINGTON



25

DATE	REVISION	BY

